



PAYNE LEAD WATER TEST RESULTS

May 9th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID ^A	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID ^B	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000232	Other	1	Spigot at south wall back of cafeteria room	WT-042816-249- A	< 1	WT-042816-249- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000231	Other	1	Spigot at north wall back of classroom 161	WT-042816-248- A	2	WT-042816-248- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000230	Utility	1	Spigot at west wall adjacent to electrical room	WT-042816-247- A	< 1	WT-042816-247- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000228	Utility	1	Spigot at north wall adjacent to natural gas meter	WT-042816-245- A	< 1	WT-042816-245- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000227	Other	1	Spigot at exterior north wall towards west wall	WT-042816-244- A	1.8	WT-042816-244- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000226	Utility	1	Spigot at north wall adjacent to basket ball court	WT-042816-243- A	< 1	WT-042816-243- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000225	Hose Bib	1	Spigot outside west wall entrance	WT-042816-242- A	37.1	WT-042816-242- B	< 1	Non-drinking water source turned off until further analysis complete		
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000221	Bathroom	2	In speech room 233, unisex restroom (shower)	WT-042816-238- A	10.9	WT-042816-238- B	6.6			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000220	Utility	2	In janitors closet	WT-042816-237- A	< 1	WT-042816-237- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000219	Bathroom	2	In speech room 233, unisex restroom	WT-042816-236- A	< 1	WT-042816-236- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000218	Bathroom	2	In boys restroom adjacent to 249 Right	WT-042816-235- A	< 1	WT-042816-235- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000217	Other	2	In speech room 233	WT-042816-234- A	2.1	WT-042816-234- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000215	Bathroom	2	In girls restroom between exit and 249 Right	WT-042816-232- A	< 1	WT-042816-232- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000213	Bathroom	2	In girls restroom between exit and 249 Left	WT-042816-230- A	< 1	WT-042816-230- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000212	Bathroom	2	In unisex restroom, adjacent to 236	WT-042816-229- A	< 1	WT-042816-229- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000210	Fountain	2	In room 246	WT-042816-227- A	3.7	WT-042816-227- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000208	Bathroom	2	In room 258, unisex restroom	WT-042816-225- A	< 1	WT-042816-225- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000207	Classroom	2	In room 258	WT-042816-224- A	1.1	WT-042816-224- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000206	Classroom	2	In room 246 Left	WT-042816-223- A	2.3	WT-042816-223- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000204	Fountain	3	In room 305	WT-042816-221- A	< 1	WT-042816-221- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000203	Break Room	3	In room 305	WT-042816-220- A	1.1	WT-042816-220- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000202	Other	3	In room 305 (fridge)	WT-042816-219- A	< 1	WT-042816-219- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000201	Break Room	3	In unisex room 305	WT-042816-218- A	< 1	WT-042816-218- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000199	Bathroom	3	In boy's restroom adjacent to room 305 Right	WT-042816-216- A	< 1	WT-042816-216- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000197	Bathroom	3	In boy's restroom adjacent to room 305 Left	WT-042816-214- A	< 1	WT-042816-214- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000196	Bathroom	3	In girls restroom facing south entrance Right	WT-042816-213- A	< 1	WT-042816-213- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000195	Utility	3	In janitors closet adjacent to room 305 (tube)	WT-042816-212- A	< 1	WT-042816-212- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000193	Bathroom	3	Girls restroom in front of south entrance Left	WT-042816-210- A	< 1	WT-042816-210- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000192	Bathroom	2	In room 207 unisex restroom (shower)	WT-042816-209- A	688	WT-042816-209- B	63.5	Non-drinking water source turned off until further analysis complete		
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000191	Fountain	2	In room 207 Right	WT-042816-208- A	< 1	WT-042816-208- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000190	Bathroom	2	In room 207 unisex restroom	WT-042816-207- A	< 1	WT-042816-207- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000189	Classroom	2	In room 207 Left	WT-042816-206- A	< 1	WT-042816-206- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000187	Utility	2	In janitors closet	WT-042816-204- A	< 1	WT-042816-204- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000186	Bathroom	2	In unisex restroom adjacent to room 208B	WT-042816-203- A	< 1	WT-042816-203- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000184	Classroom	2	In room 208B	WT-042816-201- A	< 1	WT-042816-201- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000183	Classroom	2	In room 205 restroom	WT-042816-200- A	< 1	WT-042816-200- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000180	Classroom	2	In room 205 (fountain) Right	WT-042816-197- A	< 1	WT-042816-197- B	< 1			



PAYNE LEAD WATER TEST RESULTS

May 9th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID ^A	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID ^B	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000178	Classroom	2	In room 205 Left	WT-042816-195- A	< 1	WT-042816-195- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000176	Bathroom	2	In boys restroom Right	WT-042816-193- A	< 1	WT-042816-193- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000175	Bathroom	2	Girls restroom from south entrance Right	WT-042816-192- A	< 1	WT-042816-192- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000174	Bathroom	2	In boys restroom Left	WT-042816-191- A	< 1	WT-042816-191- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000172	Bathroom	2	Girls restroom facing south entrance Left	WT-042816-189- A	< 1	WT-042816-189- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000166	Bathroom	1	In room 181 restroom	WT-042716-183- A	< 1	WT-042716-183- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000160	Bathroom	1	In room 184 restroom	WT-042716-177- A	< 1	WT-042716-177- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000159	Bathroom	1	In hallway between room 172 and 176	WT-042716-176- A	< 1	WT-042716-176- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000157	Bathroom	1	In room 172 restroom	WT-042716-174- A	< 1	WT-042716-174- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000154	Fountain	1	In hallway, adjacent to room 184 Right	WT-042716-171- A	< 1	WT-042716-171- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000152	Bathroom	1	In room 168 restroom	WT-042716-169- A	< 1	WT-042716-169- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000145	Bathroom	1	In room 187	WT-042716-162- A	< 1	WT-042716-162- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000143	Fountain	1	In room 190 (bubbler) Right	WT-042716-160- A	< 1	WT-042716-160- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000141	Classroom	1	In room 190 Right	WT-042716-158- A	1.4	WT-042716-158- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000140	Bathroom	1	In room 190 restroom	WT-042716-157- A	< 1	WT-042716-157- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000139	Bathroom	1	In room 161 restroom	WT-042716-156- A	< 1	WT-042716-156- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000136	Bathroom	1	In unisex restroom between 161 and 165	WT-042716-153- A	< 1	WT-042716-153- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000135	Utility	1	In janitor closer 165	WT-042716-152- A	2	WT-042716-152- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000133	Other	1	In room 129A (bubbler) Right	WT-042716-150- A	< 1	WT-042716-150- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000132	Bathroom	1	In room 129 unisex restroom (shower)	WT-042716-149- A	746	WT-042716-149- B	11.4	Non-drinking water source turned off until further analysis complete		
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000131	Other	1	In room 129A Left	WT-042716-148- A	1.6	WT-042716-148- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000130	Bathroom	1	In room 129 unisex restroom	WT-042716-147- A	< 1	WT-042716-147- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000129	Cooler	1	In room 131 (refrigerator)	WT-042716-146- A	< 1	WT-042716-146- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000128	Bathroom	1	In unisex restroom adjacent to 132	WT-042716-145- A	< 1	WT-042716-145- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000127	Bathroom	1	In unisex restroom 123	WT-042716-144- A	< 1	WT-042716-144- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000125	Fountain	1	In room 131 Right	WT-042716-142- A	< 1	WT-042716-142- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000123	Classroom	1	In room 131 Left	WT-042716-140- A	< 1	WT-042716-140- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000121	Bathroom	1	In unisex restroom between room 117D and 123	WT-042716-138- A	< 1	WT-042716-138- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000120	Other	1	In room 117 sink sprayer Right	WT-042716-137- A	< 1	WT-042716-137- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000119	Cooler	1	In room 117 (refrigerator)	WT-042716-136- A	< 1	WT-042716-136- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000118	Classroom	1	In room 117 Left	WT-042716-135- A	< 1	WT-042716-135- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000114	Bathroom	1	In kitchen restroom	WT-042716-131- A	< 1	WT-042716-131- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000113	Kitchen	1	In kitchen south wall sink adjacent to restroom	WT-042716-130- A	< 1	WT-042716-130- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000112	Kitchen	1	In kitchen south wall back sink Right	WT-042716-129- A	< 1	WT-042716-129- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000111	Kitchen	1	In kitchen front sink Right	WT-042716-128- A	1.6	WT-042716-128- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000110	Kitchen	1	In kitchen south wall back sink Mid	WT-042716-127- A	< 1	WT-042716-127- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000109	Kitchen	1	In kitchen facing south wall back sink (hand sprayer) Left	WT-042716-126- A	< 1	WT-042716-126- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000108	Kitchen	1	In kitchen facing south wall front sink Left	WT-042716-125- A	< 1	WT-042716-125- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000107	Kitchen	1	In kitchen north wall adjacent to refrigerator	WT-042716-124- A	< 1	WT-042716-124- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000106	Bathroom	1	In girls restroom adjacent to room 154 Right	WT-042716-123- A	< 1	WT-042716-123- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000105	Bathroom	1	In girls restroom adjacent to room 154 Left	WT-042716-122- A	< 1	WT-042716-122- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000104	Utility	1	In janitor closet room 146	WT-042716-121- A	< 1	WT-042716-121- B	< 1			



PAYNE LEAD WATER TEST RESULTS

May 9th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID ^A	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID ^B	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000103	Other	1	In room 147 unisex restroom (shower)	WT-042716-120- A	215	WT-042716-120- B	2.8	Non-drinking water source turned off until further analysis complete		
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000102	Bathroom	1	In room 147 unisex restroom	WT-042716-119- A	< 1	WT-042716-119- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000101	Bathroom	1	In boys restroom between 154 and 149 Right	WT-042716-118- A	< 1	WT-042716-118- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000100	Bathroom	1	In boys restroom between 154 and 149 Left	WT-042716-117- A	< 1	WT-042716-117- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000223	Cooler	2	In hallway, adjacent to room 233 (bottle filler) Left High	WT-042816-240- A	< 1	WT-042816-240- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000211	Cooler	2	In hallway, adjacent to room 258 (bottle filler) Left High	WT-042816-228- A	< 1	WT-042816-228- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000205	Other	1	In kitchen (ice maker) High	WT-042816-222- A	< 1	WT-042816-222- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000200	Cooler	2	In hallway adjacent to girls restroom Left High	WT-042816-217- A	< 1	WT-042816-217- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000198	Cooler	2	In hallway adjacent to girls restroom Left High	WT-042816-215- A	< 1	WT-042816-215- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000188	Cooler	2	In hallway, adjacent to boys restroom (bottle filler) Left High	WT-042816-205- A	< 1	WT-042816-205- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000182	Cooler	2	In hallway adjacent to boys restroom Left High	WT-042816-199- A	< 1	WT-042816-199- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000179	Cooler	2	In room 204 Left High	WT-042816-196- A	< 1	WT-042816-196- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000177	Cooler	2	In room 204 Left High	WT-042816-194- A	< 1	WT-042816-194- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000173	Fountain	2	In room 204 Left High	WT-042816-190- A	< 1	WT-042816-190- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000171	Classroom	2	In room 204 Left High	WT-042816-188- A	1	WT-042816-188- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000168	Fountain	1	In hallway between room 180 and 181 (bottle filler) Left High	WT-042716-185- A	< 1	WT-042716-185- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000165	Fountain	1	In room 181 Right High	WT-042716-182- A	< 1	WT-042716-182- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000161	Classroom	1	In room 172 Left High	WT-042716-178- A	< 1	WT-042716-178- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000155	Classroom	1	In room 184 Left High	WT-042716-172- A	1.8	WT-042716-172- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000149	Classroom	1	In room 187 Left High	WT-042716-166- A	2.3	WT-042716-166- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000148	Fountain	1	In room 168 Right High	WT-042716-165- A	< 1	WT-042716-165- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000147	Fountain	1	In hallway adjacent to room 184 Left High	WT-042716-164- A	< 1	WT-042716-164- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000142	Classroom	1	In room 190 Left High	WT-042716-159- A	1.6	WT-042716-159- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000138	Classroom	1	In room 161 Right High	WT-042716-155- A	< 1	WT-042716-155- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000126	Cooler	1	In hallway adjacent to room 132 (bottle filler) Left High	WT-042716-143- A	< 1	WT-042716-143- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000116	Fountain	1	In hallway adjacent to restaurant (bottle filler) Left High	WT-042716-133- A	< 1	WT-042716-133- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000224	Cooler	2	In hallway, adjacent to room 233 Right Low	WT-042816-241- A	< 1	WT-042816-241- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000222	Cooler	2	In hallway, adjacent to room 233 Left Low	WT-042816-239- A	< 1	WT-042816-239- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000214	Cooler	2	In hallway, adjacent to room 258 Right Low	WT-042816-231- A	< 1	WT-042816-231- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000209	Cooler	2	In hallway, adjacent to room 258 Left Low	WT-042816-226- A	< 1	WT-042816-226- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000194	Cooler	3	In hallway adjacent to girls restroom Right Low	WT-042816-211- A	< 1	WT-042816-211- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000185	Cooler	2	In hallway adjacent to boys restroom Right Low	WT-042816-202- A	< 1	WT-042816-202- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000181	Cooler	2	In room 204 Right Low	WT-042816-198- A	< 1	WT-042816-198- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000170	Fountain	1	In hallway between room 180 and 181 Left Low	WT-042716-187- A	< 1	WT-042716-187- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000169	Fountain	1	In hallway between room 180 and 181 Right Low	WT-042716-186- A	< 1	WT-042716-186- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000167	Classroom	1	In room 172 Right Low	WT-042716-184- A	< 1	WT-042716-184- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000164	Fountain	1	In room 181 Left Low	WT-042716-181- A	2	WT-042716-181- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000163	Classroom	1	In room 172 Right Low	WT-042716-180- A	< 1	WT-042716-180- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000162	Classroom	1	In room 181 Left Low	WT-042716-179- A	2.1	WT-042716-179- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000158	Fountain	1	In room 184 Right Low	WT-042716-175- A	< 1	WT-042716-175- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000156	Classroom	1	In room 184 Right Low	WT-042716-173- A	< 1	WT-042716-173- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000153	Classroom	1	In room 187 (bubbler) Right Low	WT-042716-170- A	1.3	WT-042716-170- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000151	Fountain	1	In hallway, adjacent to room 184 Left Low	WT-042716-168- A	< 1	WT-042716-168- B	< 1			



PAYNE LEAD WATER TEST RESULTS

May 9th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location		1st Draw - Sample ID ^A	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID ^B	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest Results
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000150	Classroom	1	In room 187	Mid Low	WT-042716-167- A	< 1	WT-042716-167- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000146	Classroom	1	In room 168 (bubbler)	Left Low	WT-042716-163- A	1.3	WT-042716-163- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000144	Classroom	1	In room 168	Left Low	WT-042716-161- A	< 1	WT-042716-161- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000137	Fountain	1	In room 161 (bubbler)	Left Low	WT-042716-154- A	< 1	WT-042716-154- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000134	Classroom	1	In room 161	Left Low	WT-042716-151- A	< 1	WT-042716-151- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000124	Cooler	1	In hallway adjacent to room 132	Left Low	WT-042716-141- A	< 1	WT-042716-141- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000122	Cooler	1	In hallway adjacent to room 132	Right Low	WT-042716-139- A	< 1	WT-042716-139- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000117	Fountain	1	In hallway adjacent to restaurant	Left Low	WT-042716-134- A	< 1	WT-042716-134- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000115	Fountain	1	In hallway adjacent to restaurant	Right Low	WT-042716-132- A	< 1	WT-042716-132- B	< 1			
PAYNE ELEMENTARY SCHOOL	4/28/2016	WS- 000099	Other	Basement	Boiler room near south wall-blue tap (water source)	Low	WT-042716-116- A	1.3	WT-042716-116- B	1.3			

Footnotes:
A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
B - Second draw sample is collected after a 60 second flush at that device after the first draw.